



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

| | |
|---|--|
| System Designation: | SG-227ea HFC-227ea Fire Extinguishing System |
| Flow Calculation Software | SG Flow Calculation Software v4.00 (SG-227ea) |
| Design, Installation, Operation, Maintenance, Software, and Owner's Manuals: | SG-227ea HFC-227ea Fire Suppression System Design, Installation and Engineering Manual Part Number: SG-UL-HFC-MNL, Rev 2 |

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Agent Extinguishing Systems

Deluge Special Hazard Fire Systems Pte Ltd.
Block 3018 Bedok North Street 5 #02-17,
Singapore 468132
Singapore

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

| <i>Approval Standards</i> | <i>Date</i> |
|-----------------------------|-------------|
| <i>Class Number</i> 5600 | August 2021 |

FM Approvals Listing Class: 5612

Original Approval Project Identification: PR464446
Subsequent Revisions: None

Approval Granted: 23 January 2023

To verify the availability of the Approved product, please refer to www.approvalguide.com


James E. Marquedant
VP, Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

23 January 2023

Date



Member of the FM Global Group