



# Certificate of Compliance

## FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

<b>System Designation:</b>	SG-FK5112 FK-5-1-12 Fire Extinguishing System
<b>Flow Calculation Software</b>	SG Flow Calculation Software v4.00 (SG-FK-5112)
<b>Design, Installation, Operation, Maintenance, Software, and Owner's Manuals:</b>	SG-FK5112 FK-5-1-12 Fire Suppression System Design, Installation and Engineering Manual Part Number: SG-UL-FK-MNL, Rev 2

*Approval Guide* Listing Category: Fixed Extinguishing Systems, Clean Agent Extinguishing Systems

Deluge Special Hazard Fire Systems Pte Ltd.  
Block 3018 Bedok North Street 5 #02-17,  
Singapore 468132  
Singapore

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

<i>Approval Standards</i>	<i>Date</i>
<i>Class Number</i> 5600	August 2021

FM Approvals Listing Class: 5612

Original Approval Project Identification: PR464446  
Subsequent Revisions: None

Approval Granted: 23 January 2023

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

  
James E. Marquedant  
VP, Manager - Electrical Systems  
FM Approvals  
1151 Boston-Providence Turnpike,  
Norwood MA, 02062 USA

23 January 2023

Date



*Member of the FM Global Group*